

TEST REPORT

REPORT NO.: 2022RE0336

PAGE : 1 OF 38

This Test Report refers only to samples submitted by the applicant to SIRIM QAS International Sdn. Bhd. and tested by SIRIM QAS International Sdn. Bhd. This Test Report shall not be reproduced, except in full and shall not be used for any purpose by any means or forms (including but not limited to advertising purposes) without written approval from the Head of Quality, Occupational Safety and Health & Environment (QOSHE), SIRIM QAS International Sdn. Bhd. Please refer to the last page of this Test Report for Conditions Relating to the Use of Test Report.

THIS TEST REPORT IS ISSUED IN SECURED PDF SOFTCOPY

Applicant : ELECOL SWITCHGEAR SDN. BHD.

Manufacturer : ELECOL SWITCHGEAR SDN. BHD.
6, Jalan 7/3, Kawasan Perindustrian Seri Kembangan
43300 Seri Kembangan, Selangor,
MALAYSIA

Product : LOW VOLTAGE MAIN SWITCH BOARD

Reference Standard / Method of test : BS EN 50121-5: 2017+A1: 2019
EN IEC 61000-6-4: 2019
EN IEC 61000-6-2: 2019

Description of Sample : Brand : ELECOL
Model/Type : MSB
Serial Number : 00001
Rating : 415 V~, 50 Hz


Date Received of Complete Application : 12 JULY 2022

Job No. : J20221410312

Overall Test Result : The test results for submitted test sample as described in this test report complied with the requirement of the above Reference Standard

Issued Date : 10 AUGUST 2022

Approved Signatories,


.....
(AZIZUL AZMAN JAAFAR)
Group Leader
EMC Laboratory




.....
(ZARISMAIL ABD RAHMAN)
Head
RF & EMC Testing Section
Testing Services Department